

The meter vault details will be reviewed by Public Utilities during site plan submittal. The meter vault details in the PFM include WD-10, WMV-1 & WMV-2. The Regional Standards WD-11 is a concrete vault for H2O loading but is not accepted without modification (Top slab cannot be one piece but must be designed in sections. This is due to limitation of equipment to lift an entire slab).

The contractor should verify the full assembly can fit prior to constructing vault.

There are 3 combination meters that the City typically accepts:

- 1) Neptune Protectus III Combination Meter
- 2) Sensus Compact Fireline Meter
- 3) Invensys Non Compact Fire line Meter

View chart to determine required vault.