



* 150 WATT (14,000 LUMENS) HPS ON 35' POLE, 2' BEHIND CURB, MOUNTING HEIGHT 30' W/ 6" ARM
 WATER SERVICE SHALL NOT BE INSTALLED ON LOTS WITH WATERMAIN ON FRONTAGE
 WATER SERVICE FOR LOTS ACROSS STREET FROM WATERMAIN SHALL BE 6" P.V.C. WITH PLUG @ RIGHT-OF-WAY LINE.
 ALL SANITARY LATERALS ARE 6" PVC @ 0.63% SDR-23.5 (UNLESS OTHERWISE NOTED)
 ALL SANITARY MANHOLES ARE TO HAVE WATERTIGHT INSERTS.
 ALL SANITARY MAINS ARE TO BE P.V.C. SDR-35 UNLESS OTHERWISE SHOWN.

MARK	REVISION	DATE	APPR.
	ADDED LIMITS OF PHASE 4	5-02-07	

SUBDIVISION OF
SUNNYSIDE MANOR
 T.P. 0500000000610 and T.P. 0500000000611
WASHINGTON BOROUGH CHESAPEAKE, VIRGINIA

**WATER AND SEWER
 CONSTRUCTION RECORD DRAWING**

XYZ ENGINEERING, INC.
 CIVIL ENGINEERS
 CHESAPEAKE, VIRGINIA

DES. A.B.C. DRN. D.E.F. CHK. G.H.I. PRJ. MGR. J.K.L.

DATE: FEB., 2008
 SCALE: 1"=25' HOR
 1"=4' VER.
 CONT. No. 00138
 DRAWING NO. 14
 OF 26