

3. BORROW PITS CHECKLIST

Plan Name _____

AC# _____ Review Engineer _____

- ___1. Setbacks (City Code Section 26-244-4)
 - ___a. 100' for borrow pits (except access roads)
 - ___b. 25' from property lines and 50' from public streets for drainage ponds.
- ___2. Access roads. (City Code Section 26-244-8)
 - ___a. Paved 75' back from public streets.
 - ___b. Intersect public streets as close to right angles as possible with a 60° minimum angle.
 - ___c. City Standard entrance required (CG-11A).
- ___3. Maximum hours of operation to be 7:00 a.m. to 7:00 p.m. and closed on Sunday. (City Code Section 26-244-9)
- ___4. Maximum 3:1 side slopes. (City Code Section 26-244-5)
- ___5. Damage to public streets.
 - ___a. Statement of methods to maintain or repair public streets used for hauling.
 - ___b. Statement of methods to keep public streets clear of loose material for 300' on both sides of the access road(s) along haul routes.
- ___6. E & S measures provided.
- ___7. List of haul routes provided.
- ___8. A borrow pit sign and detail (City Code Section 26-244-12).
- ___9. Restoration Plan Approval (City Code Section 26-244-2).
 - ___a. Restoration control plan showing proposed contours at two foot intervals and datum used.
 - ___b. Final depth of excavation and final grade of slopes.
 - ___c. Proposed dates of commencing and completing restoration activities.
 - ___d. A planting plan.