



NOTES:

1. DIRECTION OF TEE BRANCH TO BE DETERMINED BY THE LOCALITY.
2. TEE AND VALVE TO BE FLANGED.
3. TEE TO BE SAME SIZE AS EXISTING VALVE OR TAPPING VALVE.
4. MINIMUM SIZE VALVE TO BE USED IS 4" WITH NON-RISING STEM AND 2" SQUARE OPERATING NUT.

FORCE MAIN CONNECTION TO H.R.S.D. FORCE MAIN

NOT TO SCALE

REFERENCE 200,803	CATEGORY SANITARY SYSTEMS	DATE 01/03	SHEET No. 1 OF 1	DETAIL No. SS_18
----------------------	------------------------------	---------------	---------------------	---------------------

Regional Construction Standards Third Edition



DESIGN AND CONSTRUCTION STANDARDS

FORCE MAIN CONNECTION TO H.R.S.D. FORCE MAIN

08/15/03	REV. FOR INTERNET 2003	DR. BY:	DATE:
DATE	REVISIONS	CHK. BY:	DATE:
		APP. BY:	DATE:

SS_18