



STEEL CASING PIPE SELECTION CHART

DUCTILE IRON PIPE SIZE	4"	6"	8"	12"	16"
STEEL CASING PIPE SIZE (O.D.)	12	18	18	24	30

NOTES:

1. ALL JOINTS INSIDE OF CASING PIPE AND ONE JOINT BEYOND SHALL BE RESTRAINED MECHANICAL JOINTS OR AS APPROVED BY LOCALITY.

2. INSTALL CASING PIPE AS SHOWN ON DRAWINGS OR MIN. 5 FT. BEYOND EDGE OF PAVEMENT.

3. STAINLESS STEEL SPACERS

SPACERS SHALL BE BOLT-ON STYLE WITH A TWO PIECE SHELL MADE FROM T-304 STAINLESS STEEL OF A MINIMUM 14 GAUGE THICKNESS. THE SHELL SHALL BE LINED WITH A RIBBED PVC SHEET OF A 0.040" THICKNESS THAT OVERLAPS THE EDGES. RUNNERS MADE FROM UHMW POLYMER, SHALL BE ATTACHED TO RISERS AT APPROPRIATE POSITIONS TO PROPERLY LOCATE THE CARRIER WITHIN THE CASING AND TO EASE INSTALLATION. RISERS TO BE MADE FROM T-304 STAINLESS STEEL OF A MINIMUM 14 GAUGE THICKNESS AND SHALL BE ATTACHED TO THE SHELL BY MIG WELDING. ALL WELDS SHALL BE FULLY PASSIVATED. ALL FASTENERS SHALL BE MADE FROM T-304 STAINLESS STEEL. CASING SPACERS SHALL BE MODEL CCS AS MANUFACTURED BY CASCADE WATERWORKS MANUFACTURING COMPANY OF YORKVILLE, IL., MODEL SSI AS MANUFACTURED BY ADVANCE PRODUCTS & SYSTEMS, INC. OF LAFAYETTE, LA., OR APPROVED EQUAL.

4. SPACER WIDTH AND PLACEMENT INTERVALS

IN ALL INSTANCES SPACER SHOULD BE PLACED TO SUPPORT THE CARRIER WITHIN TWO FEET OF THE END OF EACH PIPE JOINT. CONSULT SPACER MANUFACTURER FOR RECOMMENDATIONS ON SPACER WIDTH AND ADDITIONAL PLACEMENT INTERVALS.

STEEL CASING DETAIL

NOT TO SCALE

REFERENCE 200,801-804	CATEGORY WATER & SANITARY	DATE 01/03	SHEET No. 2 OF 2	DETAIL No. WS_04
--------------------------	------------------------------	---------------	---------------------	---------------------

**Regional Construction
Standards
Third Edition**

_04_2.tif

SHEET 2 OF 2

		DESIGN AND CONSTRUCTION STANDARDS	
		STEEL CASING DETAIL	
08/15/03	REV. FOR INTERNET 2003	DR. BY:	DATE:
DATE	REVISIONS	CHK. BY:	DATE:
		APP. BY:	DATE:

WS_04

06