

9 VAC 25-790-50 and 60 define who must apply for a CTC. All new or expanded sewage treatment plant projects; major modifications of sewage treatment plants (if an engineer is needed, then a CTC is needed); gravity sewer projects with average day design flows over 40,000 gpd; pump station/force mains to gravity sewer with average day design flows > 2000 gpd; pump stations/force main to pressurized systems; and vacuum systems must apply for a CTC.